



511 SOUTH 7TH STREET
DELANO MN 55328
Phone: 763.972.2981
Fax: 763.972.2911

www.industriallouvers.com
ilinfo@industriallouvers.com

MODEL 613SXP

STANDARD CONSTRUCTION

Frame and blades to be 6" deep 16 ga. Galvanized Steel.

1/2" mesh 19 gauge galvanized wire bird screens in a removable formed steel frame.

Finish to be mill.

INSTALLATION

Model 613SXP should be installed in accordance with manufacturers recommended attachment method and in accordance with state and federal building codes.

WARRANTY

All materials and workmanship are warranted for a period of 1 year from date of completion.

MAINTENANCE

None required.

FEATURES

- All sizes are custom fabricated to meet project requirements.
- Integral water spouts at the jambs to drain water from the blades to the exterior of the building.
- Clip angles for installation.
- All welded assembly.

OPTIONAL ACCESSORIES

Many optional accessories to the basic design are available at an additional cost. They include:

- Extended sill flashing
- Flanged frames of various sizes
- Hinged access panels
- Subframes
- Continuous perimeter angles
- Visible or invisible mullions for multiple section requirements.
- Baked Enamel or Kynar finish

Note: Manufacturers of Kynar finishes do not warrant Kynar paint on steel.

Please contact the factory for other special requirements.

SUGGESTED SPECIFICATIONS

Furnish and install where indicated on the drawings ILI extra performance weather-resistant drainable frame Model 613SXP louvers as manufactured by Industrial Louvers, Inc., Delano, MN. Frames and blade thickness to be 18 gauge galvanized steel. The frame shall be designed to collect and drain water to exterior at sill by means of channels in the jambs. Sill and jamb frames shall be continuously welded and caulked to help prevent water penetration to interior wall construction. Blades are attached by means of all-welded construction.

The louvers shall have a minimum of 7.75 sq. ft. (48%) free area on a 48 inch x 48 inch louvers.

CATALOG NO. 613SXP

Rev: MAY 2004